



GOVERNMENT OF TRIPURA
DIRECTORATE OF FIRE & EMERGENCY
SERVICES
AGARTALA : TRIPURA



Phone: 0381-232-6451

Email: dg.fire-tr@gov.in

website:www.fireservice.tripura.gov.in

No: FSCTFES/2023/00064

Dated: 17/01/2024

Sub: FIRE SAFETY CERTIFICATE

Certified that the building or premises as mentioned below have complied with the fire prevention and fire safety requirements in accordance with the conditions laid down in the relevant portions of Part-IV of the latest National Building Code and the Tripura Building Rules and that the building/ premises is fit for occupancy class Educational for a period of 3 (three) year(s) in accordance with renewal from time to time.

Name of the Applicant:-	Joe Paul			
Name of Owner with Plot details:-	S. No.	Owner Name and Address		
	1.	দং- হ্লিক্রস এ ডুকেশনেল ফাউনডেশন এর পক্ষে চেয়ারম্যান সাং- দুর্জয়নগর		
	S. No.	Plot No	Total Area	Classification
	1.	903	3.55	----
Name of the Property/ Organization/ Commercial establishment	Holy Cross College			
Address of the Building/ Premises:-	Jubatara Habitation, Debendranagar Gram Panchayat, Bamutia Block, Post Office Lefunga B.O - 799210, West Tripura District, Tripura.			

Director,
Fire & Emergency Services,
Or Authorized Signatory
Tripura : Agartala

This certificate will expire on 17/01/2027

Conditions for the Validity of Fire Safety Certificate (NOC).

1. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
2. There should not be any change of Trade for which this License has been issued.
3. Building sanctioning authority may verify any deviation with regard to the construction/ occupancy in the building. In case of any deviation, the Fire Safety Certificate stands null and void.
4. Water reservoir should always be kept full up to brim.
5. The entrance and exit and the water reservoir should always be free from any obstruction/ projection.
6. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.

Mere issuance of this Fire Safety Certificate (NOC) (involving a B+G+3 storied educational building having 7677.5 sqm. covered area and of 14.4 m height) shall not absolve the applicant from any of legal liabilities arising from the Tripura Fire and Emergency Services Act, 2022, the TLR & LR Act, 1960, the National Building Code of India, 2016, and the Tripura Building Rules, 2017, which the applicant shall be obliged to strictly adhere to at all times.